

OFFICE OF CIVIL SURGEON,
JALANDHAR


CERTIFICATE

No: 234

Date: 24/3/21

TO WHOM IT MAY CONCERN

Certified that the team of Health Inspector inspected the Premises "**Cambridge International School for Girls Urban Estate Phase II, Jalandhar**" on the basis of the report given by the team, it is certified that the hygienic conditions of the "**Cambridge International School for Girls Urban Estate Phase II, Jalandhar**" are good at present.


Civil Surgeon, Jalandhar

Date

Place: Jalandhar

OFFICE OF CIVIL SURGEON,
JALANDHAR

CERTIFICATE

No: 234

Date: 24/3/21

TO WHOM IT MAY CONCERN

Certified that the team of Health Inspector inspected the Premises "**Cambridge International School for Girls Urban Estate Phase II, Jalandhar**" on the basis of the report given by the team, it is certified that the hygienic conditions of the "**Cambridge International School for Girls Urban Estate Phase II, Jalandhar**" are good at present.


Civil Surgeon, Jalandhar

Date

Place: Jalandhar

MUNICIPAL CORPORATION JALANDHAR

WATER TESTING LABORATORY

(WATER ANALYSIS REPORT)

REF. NO:- 517 SAMPLE PROVIDED BY:- Cambridge International School for Girls
Urban Estate, Phase II, Jalandhar.

REF. DT. 11/12/20 SAMPLE COLLECTED:-

SR. NO.	TEST	REQUIRED LIMIT IS10500	SAMPLE (1)	SAMPLE (2)	SAMPLE (3)	SAMPLE (4)
1	COLOUR	5 HAZEN	Colourless			
2	ODOUR	UNOBJECTIONABLE	Odourless			
3	TASTE	AGREEABLE	Normal			
4	PH	6.5-8.5	6.6			
5	TOTAL HARDNESS AS CaCO ₃	300 mg/l	40.0			
6	DISSOLVED SOLIDS(TDS)	500 ppm	80			
7	ALKALINITY	200 mg/l	50.0			
8	CALCIUM AS Ca ⁺⁺	75 mg/l	9.0			
9	IRON	0.3 mg/l	0.1			
10	CHLORIDE	250 mg/l	16.0			
11	SULPHATE	150 mg/l	—			
12	NITRATES	4.5 mg/l	ND			
13	RESIDUAL CHLORINE	0.2 mg/l	ND			
14	FLUORIDE	1.0 mg/l	ND			
15	LEAD	0.05 mg/l	—			
BACTERIAL TEST						
TOTAL COLIFORM COUNT						
BY MPN METHOD PER 100ML			0/10			
TOTAL E-COLI COUNT						
BY MPN METHOD PER 100ML						

REMARKS:-

The provided sample found satisfactory as per the applied tests.



Analyst
 Analyst
 Municipal Corporation
 Jalandhar 10/12/20